

BACnet CONFORMANCE CERTIFICATE



No. BTL-31353

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.20. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 26.0 and the BTL Testing Policies, see Test Report number VG 2025_1025061 of MBS.

Product name (B-ASC)
BACnet Server for EWIO2
Model(s) 110904 EWIO2-BM, 110909 EWIO2-W-BM (with WLAN), 110935 EWIO2-M-BM (with M-Bus), 110934 EWIO2-MW-BM (with both)
Firmware version
1.0.0-MC
Vendor
METZ CONNECT GmbH
Ottilienweg 9
78176 Blumberg, Germany

This certificate is valid until **31-Mar-2031**.

17-Jun-2025

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body